

Swimming Pool – The pool is used for community recreation and education such as lifeguard classes and swimming lessons.

The Transition Plan for the Municipal Swimming Pool was compiled by Thomas Doran.

Vehicular Arrival/Parking: People with disabilities are able to arrive at the site in a vehicle and park in front of the Pool Bathhouse. There is no reserved parking and there are no curbs. These parking sites are not designated by either striping or signage. There are no steps or ramps to the entrance.

Modification: No modifications are planned at this time.

Accessible Approach: There is only one route.

Building Access to Good and Services: There are no steps or ramps to the entrance and there is a sidewalk connected to the parking lot leading to the front door.

Signage for Goods and Services: There are no signs for goods and services.

Main Entrance and Doors: The outside concrete entrance area directly in front of the door easily accommodates a wheelchair. The exterior doorway is 72 inches wide and is comprised of two solid core metal doors with each side measuring 36 wide. There are no grab handles for the doors as they are always open during business hours. There is a 1 ½ inch threshold from the outside to a hard surfaced floor inside.

Entrance: The front doors lead to a small entryway which is hard surfaced and measures 50 inches by 21 foot 8 inches. This entryway leads to the dressing rooms via a 36-48 inch wide hallway that has multiple corners to navigate.

Controls: There are no controls.

Directional and Informational Signage: There are signs directing patrons to gender specific dressing areas as well as signs informing patrons of rules and regulations.

Women's Dressing Room: The women's dressing room is hard surfaced and consists of two 36 inch wide individual stalls for toilets. The toilets are 15 inches from the floor. The bottom of the sink is 28-¼ off of the floor. The sink soap dispenser is 39 inches off of the floor. The paper towel dispenser is 61-¼ inches from the floor. There are two individual showers without barriers to step over. One is 22-¾ inch wide the other is 24 inches wide. The main shower is 6 feet 1 inch wide, consists of 2 shower heads, with a 4 inch basin ledge to step over. There are no grab bars in the women's dressing room.

Men's Dressing Room: The men's dressing room is hard surfaced consists of two 30-¾ inch wide individual stalls for toilets. The toilets are 15 inches from the floor. There are two showers. An

individual shower has a 33 inch opening and a main shower (with three shower heads) has an opening of 8 feet 11-½ inches. Both have a 4 ½ inch ledge to step over. The bottom of the sink is 28-¼ off of the floor. The sink soap dispenser is 39 inches off of the floor. The paper towel dispenser is 61-¼ inches from the floor. There are no grab bars in the men's dressing room.

Office: The office is hard surfaced and measures 18 feet by 12 feet and is accessible from a 36 inch door with no barriers.

The Pool: The pool deck is hard surfaced and surrounds the pool tub. The pool tub can be accessed by a "Water Hydraulic Lift" that is handicapped ready. There is one two-step ladder in the three foot area, two four-step ladders with neoprene "Kool Grips" hand-grips covering the hand rails in the 5 foot, and two four-step ladders with neoprene "Kool Grips" hand-grips covering the hand rails in the 10 foot. The pool tub shallow area is 3 feet that gradually increases to 5 feet. The pool tub deep area has ledge surrounding it that will keep patrons at the 5 foot level. Away from the ledge the deep area slants to 7 feet and increases to 10 feet.